

CERTIFICATE OF COMPLIANCE

Certificate Number 20120703-MH45398
Report Reference MH45398-20070920
Issue Date 2012-JULY-03

Issued to: BRUGG ROHRSYSTEME GMBH
ADOLF-OSTERHELD-STRASSE 31
31515 WUNSTORF GERMANY


This is to certify that representative samples of PIPING, FLAMMABLE LIQUID, UNDERGROUND
See Addendum Page.

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: USL – Indicates investigation to Standard UL 971A.
CNL - Indicates investigation to Canadian Standard ULC-S667.

Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.

William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus



CERTIFICATE OF COMPLIANCE

Certificate Number 20120703-MH45398
Report Reference MH45398-20070920
Issue Date 2012-JULY-03

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Metallic Underground Piping for Flammable Liquids – FLEXWELL – 1/2, 1, 1-1/2, 2 and 3 in. diameter, Secon X and Secon X II – 1, 1-1/2, 2, 2-1/2, and 3 inch diameter Flexible Type Piping for use as Integral Primary/Secondary Pipe System (PS) for underground fuel transfer applications such as gas stations for Motor Vehicle (MV), High Blend (HB), Concentrated (CT) and Aviation and Marine (A&M) Fuels.

William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus

